



TOWN OF ACTON
472 Main Street
Acton, Massachusetts, 01720
Telephone (978) 929-6633
Fax (978) 929-6340

Building Department

August 23, 2013

Roland Bartl Planning Director

Re: exchange Hall accessibility

Dear Roland,

This letter is intended to give you a status update of the accessibility of Exchange Hall. At this point the Ballroom (3rd floor) and the first floor are in full compliance with the Massachusetts Architectural Access Board regulations 521 CMR. All the required accessible parking for the ballroom is installed and there are accessible bathrooms on the first and third floor. The elevator (LULA) has been inspected and approved by the state elevator examiners and me. The second floor is considered accessible but a lack of an accessible bathroom will require a variance. The cabinet business in the basement floor is not accessible because it does not have the required parking space this will require a variance or repaving.

Respectfully,

Mark Barbadoro
Building Inspector

RECEIVED

AUG 23 2013

Town of Acton
Planning Department